

Commercial pipe and piping-SUB CATEGORY-UNSPSC Code-401715													
STEEL PIPES FOR WATER AND SEWAGE-UNSPSC Code-40171501													
ITC-HS CODE- 84799090													
STEEL PIPES FOR WATER AND SEWAGE (168.3 mm to 2540 mm)													
S. NO.	PARAMETERS	Charater/ Numerical	VALUE 1	VALUE 2	VALUE 3	VALUE 4	UNIT	Remark	Validation	FILTER REQUIRED	PRIORITY	Mandatory Field	DEMAND AGGREGATION
1	Conformity to Indian Standard	CH	IS 3589 Latest							NO			Meters
2	ISI Marked	CH	YES	NO						YES	1		
3	BIS Licence Number	CH	#					Must Declare if ISI Marked		NO			
4	Method of Manufacturing	CH	Seamless (S)	Electric Resistance Including Induction Welding (ERW)	Submerged Arc Welded including Spirally Welded (SAW)					YES	2		
5	Grade	CH	Fe330	Fe410	Fe450					YES	3		
6	Outside Diameter of Pipe	Ch	#				mm	Enter the Value from 168.3 to 2540 mm	>=168.3 and <=2540	NO			
7	Thickness of Pipe	CH	#				mm			NO			
8	Length of Pipe	CH	#				Metre			NO			
9	Type of Coating	CH	Without Coating	Zinc Coating	Cement Mortar Protective Linning and Coating					YES	4		
			Liquid Epoxy Coating	Fusion Bonded Epoxy Coating	Hot Applied Tape Coating	Cold Applied Tape Coating							
10	Pipe Ends for Joint	CH	Plain Ends	Bewelled Ends	Sleeve Joints or Swelled and Plain Ends					YES	5		
11	Availability of Test Reports of from Central Govt./State Govt/NABL/IL AC accredited Lab to prove conformity to the Specification	CH	YES							NO			
12	Test report to be furnished to the buyer on demand	CH	YES							NO			
13	Test Report No	CH	#							No		#	
14	Test Report Date	CH	#							NO		#	
15	Name of the Lab	CH	#							NO		#	
16	Address of the Lab	CH	#							NO		#	

Must be Declared